

# THERMA-TRU CORPORATION ACOUSTICAL PERFORMANCE TEST REPORT

**SCOPE OF WORK**

ASTM E90 SOUND TRANSMISSION LOSS TESTING ON A  
FIBERGLASS FOAM CORE FIRE DOOR, 3068

**REPORT NUMBER**

J4862.01-113-11-R0

**TEST DATE**

05/23/19

**ISSUE DATE**

07/02/19


**PAGES**

18

**DOCUMENT CONTROL NUMBER**

RT-R-AMER-Test-2756 (01/24/19)

© 2017 INTERTEK



## TEST REPORT FOR THERMA-TRU CORPORATION

Report No.: J4862.01-113-11-R0

Date: 07/02/19

### REPORT ISSUED TO

#### THERMA-TRU CORPORATION

6214 Monciov Road  
Maumee, Ohio 43537

### SECTION 1

#### SCOPE

Intertek Building & Construction (B&C) was contracted by Therma-Tru Corporation to conduct a sound transmission loss test. Results obtained are tested values and were secured by using the designated test methods. The complete test data is included herein. The client provided the test specimen. All measurements were conducted in the HT test chambers at Intertek B&C located in York, Pennsylvania.

This report does not constitute certification of this product nor an opinion or endorsement by this laboratory. Intertek B&C will service this report for the entire test record retention period. The test record retention period ends four years after the test date. Test records, such as detailed drawings, datasheets, representative samples of test specimens, or other pertinent project documentation, will be retained for the entire test record retention period.

For INTERTEK B&C:

<b>COMPLETED BY:</b>	Zachary P. Golden	<b>REVIEWED BY:</b>	Todd D. Kister
<b>TITLE:</b>	Technician Team Leader Acoustical Testing	<b>TITLE:</b>	Laboratory Manager Acoustical Testing
<b>SIGNATURE:</b>		<b>SIGNATURE:</b>	
<b>DATE:</b>	07/02/19	<b>DATE:</b>	07/02/19

ZPG:jmcs

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample(s) tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



**TEST REPORT FOR THERMA-TRU CORPORATION**

Report No.: J4862.01-113-11-R0

Date: 07/02/19

**SECTION 2****SUMMARY OF TEST RESULTS****OPTION A**

<b>SERIES/MODEL</b>	Fiberglass Foam Core Fire Door
<b>TYPE</b>	3068 with 1" hinge stile

<b>TEST CONDITION</b>	Inoperable (Sealed with duct seal on both sides)
<b>DATA FILE NO.</b>	J4862.01A
<b>STC</b>	24
<b>OITC</b>	25

<b>TEST CONDITION</b>	Operable
<b>DATA FILE NO.</b>	J4862.01A1
<b>STC</b>	24
<b>OITC</b>	24

**OPTION B**

<b>SERIES/MODEL</b>	Fiberglass Foam Core Fire Door
<b>TYPE</b>	3068 with 4" hinge stile

<b>TEST CONDITION</b>	Inoperable (Sealed with duct seal on both sides)
<b>DATA FILE NO.</b>	J4862.01B
<b>STC</b>	24
<b>OITC</b>	25

<b>TEST CONDITION</b>	Operable
<b>DATA FILE NO.</b>	J4862.01B1
<b>STC</b>	24
<b>OITC</b>	24

## TEST REPORT FOR THERMA-TRU CORPORATION

Report No.: J4862.01-113-11-R0

Date: 07/02/19

### SECTION 3

#### TEST METHODS

The specimens were evaluated in accordance with the following:

**ASTM E90-09 (2016)**, *Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements*

**ASTM E413-16**, *Classification for Rating Sound Insulation*

**ASTM E1332-16**, *Standard Classification for Rating Outdoor-Indoor Sound Attenuation*

**ASTM E2235-04 (2012)**, *Standard Test Method for Determination of Decay Rates for Use in Sound Insulation Test Methods*

### SECTION 4

#### SPECIMEN INSTALLATION

A sound transmission loss test was initially performed on a filler wall.

The specimen plug was removed from the filler wall assembly. The specimen was placed on an isolation pad in the test opening. Duct seal was used to seal the perimeter of the specimen to the test opening on both sides. The interior side of the specimen, when installed, was approximately 1/4" from being flush with the receive room side of the filler wall. A stethoscope was used to check for any abnormal air leaks around the test specimen prior to testing. Operable portions of the test specimen, if any, were cycled at least five times prior to testing.

## TEST REPORT FOR THERMA-TRU CORPORATION

Report No.: J4862.01-113-11-R0

Date: 07/02/19

### SECTION 5 EQUIPMENT

The equipment listed below meets the requirements of the test methods stated in Section 3 of this report.

INSTRUMENT	MANUFACTURER	MODEL	DESCRIPTION	ASSET #	CAL DATE
Data Acquisition Card	National Instruments	PXI-4462	Data Acquisition Card	65125*	05/18
Data Acquisition Card	National Instruments	PXI-4462	Data Acquisition Card	65126*	05/18
Data Acquisition Card	National Instruments	PXI-4462	Data Acquisition Card	63763-3*	04/18
Source Room Microphone	PCB Piezotronics	378B20	Microphone and Preamplifier	64902	12/18
Source Room Microphone	PCB Piezotronics	378C20	Microphone and Preamplifier	64903	05/18
Source Room Microphone	PCB Piezotronics	378C20	Microphone and Preamplifier	65103	03/19
Source Room Microphone	PCB Piezotronics	378C20	Microphone and Preamplifier	65905	03/19
Source Room Microphone	PCB piezotronics	378C20	Microphone and Preamplifier	65906	03/19
Receive Room Microphone	PBC Piezotronics	378B20	Microphone and Preamplifier	64907	12/18
Receive Room Microphone	PCB Piezotronics	378B20	Microphone and Preamplifier	64908	12/18
Receive Room Microphone	PCB Piezotronics	378B20	Microphone and Preamplifier	64909	12/18
Receive Room Microphone	PCB Piezotronics	378B20	Microphone and Preamplifier	64910	12/18
Receive Room Microphone	PCB Piezotronics	378B20	Microphone and Preamplifier	64911	01/19
Receive Room Environmental Indicator	Comet	T7510	Receive Room	64915	01/19
Source Room Environmental Indicator	Comet	T7510	Source Room	64914	03/19
Microphone Calibrator	Larson Davis	CAL200	Acoustical Calibrator	INT00852	09/18

\*- Note: The calibration frequency for this equipment is every two years per the manufacturer's recommendation.

### TEST CHAMBER

	VOLUME	DESCRIPTION
RECEIVE ROOM	234 m <sup>3</sup>	Rotating vane and stationary diffusers Temperature and humidity controlled Isolation pads under the floor
SOURCE ROOM	207 m <sup>3</sup>	Stationary diffusers only Temperature and humidity controlled

	MAXIMUM SIZE	DESCRIPTION
TL TEST OPENING	4.27 m wide by 3.05 m high	Vibration break between source and receive rooms

## TEST REPORT FOR THERMA-TRU CORPORATION

Report No.: J4862.01-113-11-R0

Date: 07/02/19

### SECTION 6

#### LIST OF OFFICIAL OBSERVERS

NAME	COMPANY
Kurt A. Golden	Intertek B&C
Zachary P. Golden	Intertek B&C

### SECTION 7

#### TEST PROCEDURE

The sensitivity of the microphones was checked before measurements were conducted.

The transmission loss values were obtained for a single direction of measurement.

Two background noise sound pressure level and five sound absorption measurements were conducted at each of five microphone positions.

Two sound pressure level measurements were made simultaneously in receive and source rooms at each of five microphone positions.

The air temperature and relative humidity conditions were monitored and recorded during all measurements.

Data for flanking limit tests, repeatability measurements, and reference specimen tests are available upon request.

Intertek B&C will store samples of test specimens for four years.

### SECTION 8

#### ACOUSTICAL TEST CALCULATIONS

Transmission loss (TL) at each 1/3 octave frequency is the average source room sound pressure level minus the average receive room sound pressure level, plus, 10 times the log of the specimen area divided by the sound absorption of the receive room with the sample in place.

#### STC Rating

To obtain the Sound Transmission Class (STC), read the TL of the contour curve at 500 Hz. The sum of the deficiencies below the contour curve must not exceed 32. The maximum deficiency at any one frequency must not exceed 8.

**TEST REPORT FOR THERMA-TRU CORPORATION**

Report No.: J4862.01-113-11-R0

Date: 07/02/19

**OITC Rating**

The Outdoor-Indoor Transmission Class (OITC) is calculated by subtracting the logarithmic summation of the TL values from the logarithmic summation of the A-weighted transportation noise spectrum stated in ASTM E1332.

**SECTION 9**

**SPECIMEN DESCRIPTION**

	<b>FRAME</b>
<b>SIZE</b>	37-1/2" by 82"
<b>THICKNESS</b>	4-9/16"
CORNERS	Butted
FASTENERS	Screws
SEAL METHOD	Sealant
<b>MATERIAL: HEAD AND JAMBS</b>	Wood
<b>MATERIAL: SILL</b>	Aluminum
REINFORCEMENT	N/A
THERMAL BREAK MATERIAL	N/A
<b>DAYLIGHT OPENING SIZE</b>	N/A

**LEAF SIZE**

36" wide by 79-1/2" high by 1-11/16" thick

<b>LEAF LAYERS (OUTSIDE TO INSIDE)</b>	<b>LAYER DESCRIPTION (MATERIAL AND THICKNESS)</b>
1	0.090" Fiberglass
2	1-1/2" Polystyrene foam
3	0.090" Fiberglass

*N/A-Not Applicable*

**OPTION A**

There was 1" by 1-1/2" engineered wood reinforcing the hinge stile and bottom rail and 4" by 1-1/2" engineered wood reinforcing the lock stile and top rail.

**OPTION B**

There was 1" by 1-1/2" engineered wood reinforcing bottom rail and 4" by 1-1/2" engineered wood reinforcing the hinge stile, lock stile and top rail.

**TEST REPORT FOR THERMA-TRU CORPORATION**

Report No.: J4862.01-113-11-R0

Date: 07/02/19

	TYPE	QUANTITY	LOCATION
<b>WEATHERSTRIP</b>	Therma-Tru Long Reach foam-filled	1 Row	Head and lock jamb
	Q-Lon® p/n QEBD-825 foam-filled	1 Row	Hinge jamb
	Therma-Tru double bulb PVC door bottom	1 Row	Bottom rail
<b>HARDWARE</b>	Hinge	3	Hinge stile
	Lock assembly set	1	Lock stile
	Keeper	2	Keeper jamb
<b>DRAINAGE</b>	Sloped sill	1	Sill

OPTION	TOTAL WEIGHT (lbs)	AVERAGE WEIGHT (lbs/ft <sup>2</sup> )
A	81	3.79
B	85	3.98

Photographs are included in Section 11.

The client did not supply a report drawing of the test specimen.



## TEST REPORT FOR THERMA-TRU CORPORATION

Report No.: J4862.01-113-11-R0

Date: 07/02/19

### SECTION 10

#### TEST RESULTS

#### J4862.01A DATA (INOPERABLE CONDITION)

<b>SPECIMEN AREA</b>	1.98 m <sup>2</sup>	<b>RECEIVE TEMP.</b>	21.1 °C	<b>SOURCE TEMP</b>	21.1 °C
<b>TECHNICIAN</b>	Zachary Gol	<b>RECEIVE HUMIDITY</b>	48%	<b>SOURCE HUMIDIT</b>	48%

FREQ (Hz)	BACKGROUND SPL (dB)	ABSORPTION (m <sup>2</sup> )	SOURCE SPL (dB)	RECEIVE SPL (dB)	SPECIMEN TL (dB)	95% CONFIDENCE LIMIT	NUMBER OF DEFICIENCIES
80	43.7	5.9	103	78	22	1.76	-
100	38.6	6.0	104	79	20	1.61	-
125	42.5	7.0	105	78	21	1.40	0
160	47.1	5.7	107	81	22	0.69	0
200	43.5	5.2	106	81	21	0.67	0
250	42.8	5.5	103	75	23	0.66	0
315	38.6	5.8	102	74	24	0.40	0
400	33.2	6.0	101	71	25	0.48	0
500	27.4	6.2	102	69	28	0.32	0
630	25.7	5.9	102	68	29	0.33	0
800	24.9	6.1	100	66	29	0.19	0
1000	23.2	6.2	101	66	30	0.31	0
1250	24.9	6.8	100	64	30	0.16	0
1600	22.9	7.1	99	64	30	0.26	0
2000	21.9	7.7	100	71	23	0.37	5
2500	19.2	8.8	100	73	20	0.25	8
3150	18.1	10.4	99	62	30	0.16	0
4000	14.2	12.9	97	50	39	0.42	0
5000	11.3	16.5	97	45	43	0.29	-
<b>STC RATING</b>	24 (Sound Transmission Class)						
<b>DEFICIENCIES</b>	13 (Sum of Deficiencies)						
<b>OITC RATING</b>	25 (Outdoor-Indoor Transmission Class)						

**Notes:**


- 1) Receive Room levels less than 5 dB above the Background levels are red.
- 2) Specimen TL levels listed in red indicate the lower limit of the transmission loss.
- 3) Specimen TL levels listed in green indicate that there has been a filler wall correction applied

## TEST REPORT FOR THERMA-TRU CORPORATION

Report No.: J4862.01-113-11-R0

Date: 07/02/19

### J4862.01A GRAPH (INOPERABLE CONDITION)



## TEST REPORT FOR THERMA-TRU CORPORATION

Report No.: J4862.01-113-11-R0

Date: 07/02/19

### J4862.01A1 DATA (OPERABLE CONDITION)

<b>SPECIMEN AREA</b>	1.98 m <sup>2</sup>	<b>RECEIVE TEMP.</b>	21.2 °C	<b>SOURCE TEMP</b>	21.2 °C
<b>TECHNICIAN</b>	Zachary Gol	<b>RECEIVE HUMIDITY</b>	48%	<b>SOURCE HUMIDIT</b>	48%

FREQ (Hz)	BACKGROUND SPL (dB)	ABSORPTION (m <sup>2</sup> )	SOURCE SPL (dB)	RECEIVE SPL (dB)	SPECIMEN TL (dB)	95% CONFIDENCE LIMIT	NUMBER OF DEFICIENCIES
80	42.4	5.7	103	78	22	1.72	-
100	37.0	5.0	104	80	21	1.53	-
125	40.3	6.2	105	79	21	1.37	0
160	45.0	5.3	106	81	21	0.89	0
200	41.6	5.2	106	81	21	0.78	0
250	40.8	5.5	102	76	22	0.61	0
315	37.7	5.9	103	74	23	0.29	0
400	29.5	6.1	101	72	25	0.38	0
500	24.7	6.2	102	70	27	0.42	0
630	23.2	6.0	102	69	28	0.44	0
800	23.8	6.2	100	67	28	0.24	0
1000	22.1	6.4	101	68	28	0.37	0
1250	24.3	6.9	100	66	28	0.12	0
1600	24.1	7.3	99	65	28	0.16	0
2000	23.3	7.8	100	71	23	0.30	5
2500	20.0	9.0	100	73	20	0.19	8
3150	18.7	10.3	99	62	30	0.14	0
4000	15.7	13.0	97	54	35	0.29	0
5000	13.3	16.6	97	50	38	0.30	-
<b>STC RATING</b>	24 (Sound Transmission Class)						
<b>DEFICIENCIES</b>	13 (Sum of Deficiencies)						
<b>OITC RATING</b>	24 (Outdoor-Indoor Transmission Class)						

**Notes:**


- 1) Receive Room levels less than 5 dB above the Background levels are red.
- 2) Specimen TL levels listed in red indicate the lower limit of the transmission loss.
- 3) Specimen TL levels listed in green indicate that there has been a filler wall correction applied

## TEST REPORT FOR THERMA-TRU CORPORATION

Report No.: J4862.01-113-11-R0

Date: 07/02/19

### J4862.01A1 GRAPH (OPERABLE CONDITION)



## TEST REPORT FOR THERMA-TRU CORPORATION

Report No.: J4862.01-113-11-R0

Date: 07/02/19

### J4862.01B DATA (INOPERABLE CONDITION)

<b>SPECIMEN AREA</b>	1.98 m <sup>2</sup>	<b>RECEIVE TEMP.</b>	21.3 °C	<b>SOURCE TEMP</b>	21.2 °C
<b>TECHNICIAN</b>	Zachary Gol	<b>RECEIVE HUMIDITY</b>	49%	<b>SOURCE HUMIDITY</b>	48%

FREQ (Hz)	BACKGROUND SPL (dB)	ABSORPTION (m <sup>2</sup> )	SOURCE SPL (dB)	RECEIVE SPL (dB)	SPECIMEN TL (dB)	95% CONFIDENCE LIMIT	NUMBER OF DEFICIENCIES
80	41.8	6.1	103	78	21	1.62	-
100	35.8	5.8	105	80	20	1.64	-
125	38.6	6.1	105	79	21	1.37	0
160	44.7	5.4	107	81	22	0.73	0
200	40.3	4.9	106	81	22	0.79	0
250	37.7	5.5	103	76	23	0.56	0
315	35.0	5.5	102	74	24	0.36	0
400	27.3	6.0	101	71	26	0.30	0
500	23.2	6.2	101	69	27	0.37	0
630	21.8	5.8	102	68	29	0.48	0
800	20.7	6.1	100	66	29	0.26	0
1000	17.8	6.4	101	66	30	0.32	0
1250	18.8	6.8	100	64	31	0.18	0
1600	17.1	7.1	99	64	30	0.17	0
2000	15.9	7.6	100	70	24	0.30	4
2500	12.8	8.8	100	73	20	0.22	8
3150	10.9	10.2	99	63	29	0.13	0
4000	9.8	12.7	97	50	39	0.31	0
5000	9.9	16.3	97	46	42	0.32	-
<b>STC RATING</b>	24 (Sound Transmission Class)						
<b>DEFICIENCIES</b>	12 (Sum of Deficiencies)						
<b>OITC RATING</b>	25 (Outdoor-Indoor Transmission Class)						


- Notes:**
- 1) Receive Room levels less than 5 dB above the Background levels are red.
  - 2) Specimen TL levels listed in red indicate the lower limit of the transmission loss.
  - 3) Specimen TL levels listed in green indicate that there has been a filler wall correction applied

## TEST REPORT FOR THERMA-TRU CORPORATION

Report No.: J4862.01-113-11-R0

Date: 07/02/19

### J4862.01B GRAPH (INOPERABLE CONDITION)



## TEST REPORT FOR THERMA-TRU CORPORATION

Report No.: J4862.01-113-11-R0

Date: 07/02/19

### J4862.01B1 DATA (OPERABLE CONDITION)

<b>SPECIMEN AREA</b>	1.98 m <sup>2</sup>	<b>RECEIVE TEMP.</b>	21.3 °C	<b>SOURCE TEMP</b>	21.2 °C
<b>TECHNICIAN</b>	Zachary Gol	<b>RECEIVE HUMIDITY</b>	49%	<b>SOURCE HUMIDIT</b>	49%

FREQ (Hz)	BACKGROUND SPL (dB)	ABSORPTION (m <sup>2</sup> )	SOURCE SPL (dB)	RECEIVE SPL (dB)	SPECIMEN TL (dB)	95% CONFIDENCE LIMIT	NUMBER OF DEFICIENCIES
80	44.0	5.7	103	78	22	1.72	-
100	38.4	6.2	105	80	20	1.59	-
125	37.7	6.6	105	79	20	1.49	0
160	41.8	5.3	107	81	21	0.86	0
200	39.5	4.9	106	81	21	0.70	0
250	31.5	5.5	103	76	22	0.63	0
315	25.1	5.7	102	74	24	0.34	0
400	23.0	6.0	102	72	25	0.40	0
500	22.1	6.2	101	70	27	0.40	0
630	19.9	5.9	102	69	28	0.42	0
800	17.2	6.2	100	68	27	0.21	0
1000	24.1	6.4	101	68	28	0.39	0
1250	10.5	6.9	100	66	29	0.16	0
1600	8.9	7.3	99	65	29	0.13	0
2000	9.9	7.7	100	70	23	0.28	5
2500	8.3	8.8	100	73	20	0.21	8
3150	8.1	10.3	99	63	29	0.14	0
4000	8.7	12.8	97	54	35	0.26	0
5000	9.6	16.5	97	50	38	0.26	-
<b>STC RATING</b>	24 (Sound Transmission Class)						
<b>DEFICIENCIES</b>	13 (Sum of Deficiencies)						
<b>OITC RATING</b>	24 (Outdoor-Indoor Transmission Class)						

**Notes:**


- 1) Receive Room levels less than 5 dB above the Background levels are red.
- 2) Specimen TL levels listed in red indicate the lower limit of the transmission loss.
- 3) Specimen TL levels listed in green indicate that there has been a filler wall correction applied

## TEST REPORT FOR THERMA-TRU CORPORATION

Report No.: J4862.01-113-11-R0

Date: 07/02/19

### J4862.01B1 GRAPH (OPERABLE CONDITION)





## TEST REPORT FOR THERMA-TRU CORPORATION

Report No.: J4862.01-113-11-R0

Date: 07/02/19

### SECTION 11

### PHOTOGRAPHS



**Photo No. 1**  
**Receive Room View of Installed Test Specimen**



**Photo No. 2**  
**Source Room View of Installed Test Specimen**



Total Quality. Assured.

130 Derry Court  
York, Pennsylvania 17406

Telephone: 717-764-7700  
Facsimile: 717-764-4129  
[www.intertek.com/building](http://www.intertek.com/building)

## TEST REPORT FOR THERMA-TRU CORPORATION

Report No.: J4862.01-113-11-R0

Date: 07/02/19

### SECTION 12

#### REVISION LOG

REVISION #	DATE	PAGES	REVISION
0	07/02/19	N/A	Original Report Issue